


FIRE RESCUE



Mike Burton
FIRE CHIEF

Fire Alarm Pull Station Notification Sign Specifications

**Local Alarm
Only
In Case of Fire**

EXAMPLE ABOVE NOT TO SCALE

- 1) The letters shall be red on a white background
- 2) The minimum height of each letter shall be 1/2 inch.
- 3) The minimum stroke width of each letter shall be 1/8 inch.
- 4) The sign shall be durable waterproof and fade resistant.
- 5) The sign shall be located no higher than 4 inches directly above the fire alarm pull station.
- 6) The sign shall be a minimum of 2 1/2 inches in height and a minimum 5 inches in width.

Code Reference:
Florida Fire Prevention Code 8th
Edition, NFPA 101, Section 31.3.4.3.5.1

REVISIONS		
No.	Date	Remarks

Date: 9/1/2024

Seal:

**TAMARAC FIRE RESCUE
STANDARD DETAILS**

CITY OF TAMARAC, BROWARD COUNTY, FLORIDA