



NOTES:

FIRE DEPARTMENT CONNECTION SIGN

2. EACH FIRE DEPARTMENT CONNECTION SHALL BE DESIGNATED BY A SIGN, WITH LETTERS AT LEAST 1 IN. (25.4 MM) IN HEIGHT, THAT READS "STANDPIPE." FOR MANUAL SYSTEMS, THE SIGN SHALL ALSO INDICATE THAT THE SYSTEM IS MANUAL AND THAT IT IS EITHER WET OR DRY.
3. IF AUTOMATIC SPRINKLERS ARE ALSO SUPPLIED BY THE FIRE DEPARTMENT CONNECTION, THE SIGN OR COMBINATION OF SIGNS SHALL INDICATE BOTH DESIGNATED SERVICES (E.G. "STANDPIPE AND "AUTOSPKR" OR "AUTOSPKR AND STANDPIPE").
4. A SIGN SHALL ALSO INDICATE THE PRESSURE REQUIRED AT THE INLETS TO DELIVER THE SYSTEM DEMAND.
5. WHERE A FIRE DEPARTMENT CONNECTION SERVICES MULTIPLE BUILDINGS, STRUCTURES, OR LOCATIONS, A SIGN SHALL BE PROVIDED INDICATING THE BUILDINGS, STRUCTURES, OR LOCATION SERVED.
6. FIRE DEPARTMENT CONNECTIONS SHALL BE LOCATED NOT LESS THAN 18 IN. (457 MM) NOR MORE THAN 48 IN. (1219 MM) ABOVE THE LEVEL OF THE ADJOINING GROUND, SIDEWALK, OR GRADE SURFACE.
7. FIRE DEPARTMENT CONNECTION PIPING SHALL BE SUPPORTED IN ACCORDANCE WITH SECTION 6.5.

REVISIONS		
No.	Date	Remarks

Date: 9/1/2024

Seal:

**TAMARAC FIRE RESCUE
STANDARD DETAILS**
CITY OF TAMARAC, BROWARD COUNTY, FLORIDA